

Number	19-003260-PR01 (NW-H05-05-en-01)
Owner	Salinox LTD Konstantinoupoleos 84 & Makedonias 50 Acharnes 13671 Athens Greece
Product	Railing with linear bearing on one side
Designation	Shipping name: U-BASE TYPE A
Details	Overall dimensions (W x H) 3010 mm x 1300 mm; Glass configuration HSG 10 mm / PVB 1.52 mm / HSG 10 mm; Thickness 21.52 mm
Special features	-/-

Result

Testing the impact resistance of glazing according to DIN 18008-4:2013-07



Category B - drop height 700 mm:
Passed

Basis

DIN 18008-4:2013-07

Test report: 19-003260-PR01 PB-H05-05-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

24.04.2020



Frank Zirbel, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing



Stefan Hehn, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 22E-027FF